



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/05/2026

Shift: A

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 8A	LT NOT TAKING PLACE/DRIVE TRIPPED ON OLR	RESET DONE	08:45:00	09:00:00	
2	CHP	CC 29	TRIPPED ON OLR	RESET DONE	09:00:00	09:10:00	
3	CHP	CC 19	TRIPPED ON OLR	RESET DONE 2 TIMES	11:00:00	11:10:00	
4	CHP	CC 51	MPD TRIPPED ON OLR /3TIMES	RESET DONE	08:50:00 10:08:00	09:00:00 10:15:00	
5	CHP	CC131	TRIPPED ON OLR	RESET DONE	09:10:00	09:15:00	
6	CHP	CC 52	MPD TRIPPED ON OLR	RESET DONE	08:30:00	08:35:00	
7	CHP	SCR 7 ON CC39	BC NOT RUNNING/30 DEGREE LIMIT ACTED	LIMIT RELEASED	06:40:00	06:50:00	
8	CHP	SCR 7 CC 39	LT NOT TAKING PLACE	DRIVE TRIPPED ON OLR	06:09:00	10:05:00	
9	CHP	SCR 1 ON CC 31	BC NOT RUNNING /30 DEGREE LIMIT ACTED DUE TO MATERIAL	LIMIT RELEASED11	11:15:00	11:30:00	
10	CHP	CC 125	TRIPPED ON OLR	RESET DONE	12:15:00	12:25:00	