



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 04/05/2026

Area: WT

Equipment	Job
CT	2 NO OF EXHAUST FANS IR VALUE CHECKED .. FUSE FIXED AND CHARGED
MIS	50 NO OF INSULATORS DISMANTLED AND 23 ASSEMBLED
OT-4	LS-2 POSITION CHANGED