



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/10/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 32 LT	SKEW limit acted	SKEW adjusted	15:45:00	16:00:00	
2	OHP	CO 25	OLR acted	Reset	16:00:00	16:10:00	
3	OHP	CO 14b	OLR acted	Reset	21:20:00	21:30:00	
4	OHP	TT3 not moving	Mpcb Tripped due to Motor TB problem	Properly fixed then ok	14:30:00	14:45:00	
5	CHP	CC 28	OLR acted	Reset	19:15:00	19:20:00	