



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/06/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-32	SKEW LIMIT ACTING	INFORMED OPERATION	02:10:00 22:35:00 23:25:00	02:30:00 22:55:00 23:45:00	
2	OHP	CO-29	STOPPING ON ZSS	MECH PROBLEM	01:06:00	01:20:00	
3	CHP	CC-105 SCR-10	BC NOT WORKING	SIGNAL MISSING ... LT DONE THEN OK	04:15:00	04:35:00	
4	CHP	CC-52 TIS	MPCB TRIPPED	MADE ON	23:05:00	23:15:00	
5	WT	OT-3	TRIPPED ON 7 SATURATION FAULT 3 TIMES	RESET DONE	05:20:00	05:35:00	