



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 17/07/2026

Area: WT

| Equipment       | Job                                                                       |
|-----------------|---------------------------------------------------------------------------|
| DE 2            | Fan Motor testing done in no load                                         |
| OP 7,8 and CP 1 | # Phase Indicator Lamps installation and connection done on pushers       |
| LC 10A          | Area lighting ,350W LEDs installation and connection done at four corners |
| OT 1            | Cabin area one 200W LED and 2 nos Tubes installed                         |
| MIS             | Preparatory job done for OT 5 track indication device                     |