



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/07/2026

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-7A	L/LUFFING OLR ACTED	RESET DONE	23:50:00	00:15:00	
2	OHP	VS-2A	OLR ACTED	RESET DONE	04:10:00	04:15:00	
3	OHP	CC-36 S1	LT M1 OLR TRIP	RESET DONE	03:25:00	03:40:00	
4	CHP	CC-36 S1	LT M-5 OLR ACTED	RESET DONE	22:40:00	22:50:00	
5	CHP	CC-40 SCR-7	B/C OLR ACTED	RESET DONE	23:10:00	23:25:00	
6	CHP	CC-213SCR-9	SLEW MCB TRIP	RESET DONE	02:50:00	03:00:00	
7	CHP	CC-112 S-3	LUFFING MCCB TRIP	MADE ON	02:55:00	03:10:00	
8	CHP	CC-131	OLR ACTED	RESET DONE	00:25:00	00:30:00	