



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/08/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	Olr acted	Reset	17:30:00	21:40:00	2 times
2	OHP	co 26	Olr Acted	Reset	15:50:00	16:00:00	
3	OHP	WBR on CO 29	Interlock ZSS probe damaged	Replaced	20:50:00	21:10:00	
4	CHP	CC 131	Olr acted	Reset	14:15:00	18:00:00	2 Times
5	CHP	CC 54	Olr acted	Reset	15:00:00	15:10:00	
6	CHP	SCR 3 on CC 37	LT Drive trip	Reset	20:20:00	20:30:00	
7	CHP	CC 125b	Olr acted	Reset	20:55:00	21:00:00	
8	CHP	All yard conv Red	Processor B in Rack 0 Power kept off	Then OK	20:30:00	20:50:00	
9	WT	CP 4	Breaker trip	Reset	17:00:00	17:10:00	
10	WT	AF2	Drive Trip	Reset	16:00:00	16:10:00	