



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/07/2026

Shift: C

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment         | Problem                      | Action                                                                                                                                        | From                 | To                   | Remarks |
|-------|------|-------------------|------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------|----------------------|----------------------|---------|
| 1     | OHP  | TBS-21            | CJD bypass                   | CJD, RMU terminations tightened and restored CJD in circuit. TBS Boom run signal Latch has been programmed and indication provided in OCR HMI | 22:30:00             | 23:30:00             |         |
| 2     | OHP  | WBR ON CO 29      | B/C ZSS PROBE IS HAVING DUST | PROPERLY CLEANED                                                                                                                              | 02:00:00             | 02:15:00             |         |
| 3     | OHP  | CO 26             | OLR ACTED                    | RESET                                                                                                                                         | 05:35:00             | 05:45:00             |         |
| 4     | OHP  | AF2               | OLR ACTED                    | RESET                                                                                                                                         | 22:20:00             | 23:05:00             | 2 TIMES |
| 5     | OHP  | CO 16             | OLR ACTED                    | RESET                                                                                                                                         | 05:40:00             | 05:45:00             |         |
| 6     | OHP  | VS 5A             | OLR ACTED                    | RESET                                                                                                                                         | 01:40:00             | 01:50:00             |         |
| 7     | CHP  | CC 131            | OLR ACTED                    | RESET                                                                                                                                         | 22:30:00             | 04:30:00             | 2 TIMES |
| 8     | CHP  | CC 54             | OLR ACTED                    | RESET                                                                                                                                         | 00:45:00             | 00:50:00             |         |
| 9     | CHP  | VS3               | OLR ACTED                    | RESET                                                                                                                                         | 22:30:00             | 22:40:00             |         |
| 10    | CHP  | CC 52 TIS         | CHAIN BROKEN                 | INFORMED TO MECH                                                                                                                              | 01:15:00             | 01:30:00             |         |
| 11    | CHP  | CC 215            | OLR ACTED                    | RESET                                                                                                                                         | 04:00:00             | 04:10:00             |         |
| 12    | CHP  | CC 31             | OLR ACTED                    | RESET                                                                                                                                         | 22:05:00             | 22:15:00             |         |
| 13    | CHP  | SCR 2 ON CC 33 LT | PCRD DRUM SENSOR ACTED       | RESET                                                                                                                                         | 23:00:00             | 23:10:00             |         |
| 14    | CHP  | CC 107            | OLR ACTED                    | RESET                                                                                                                                         | 04:10:00<br>05:40:00 | 04:15:00<br>05:45:00 |         |