वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 23/10/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 28	OLR acted	Reset	21:20:00	21:30:00	
2	OHP	TBS on CO 20 Lt	M1 trip due to jamming	Reset	16:55:00	17:10:00	
3	OHP	CO 26	OLR acted	Reset	18:25:00	18:35:00	
4	OHP	VF1a	M1 OLR acted	Reset	17:50:00	18:00:00	
5	OHP	CO 56	core loose near OLR	Tightened	20:10:00	20:20:00	
6	CHP	CC 28	OLR acted	Reset	18:30:00	18:50:00	2 times
7	CHP	CC 201	OLr acted	Reset	14:30:00	14:35:00	