



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/06/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	tripped on olr	reset done	01:50:00	02:00:00	
2	OHP	co 76r	tripped on olr	reset done	01:50:00	02:00:00	
3	OHP	co 34	tripped on olr	reset done	22:00:00	22:10:00	
4	OHP	brc on co 28	bc not running/olr acted	reset done	22:00:00	22:15:00	
5	OHP	WOBR on CO 6A	yard indication not coming,zss cage tied to rope	zss installed on conveyor	23:10:00	23:20:00	
6	OHP	WOBR on co 25	LT not working,PCRD tension acted,side chain broken	informed mechanical	01:30:00	01:40:00	
7	OHP	CO 26	OLR acted	reset	01:40:00	01:45:00	
8	OHP	WOBR on CO 25	LT not working,pcrd chain broken,pcrd LS high return not coming	informed mechanical	04:40:00	05:10:00	
9	CHP	CC 51	mpd acted 2 times	reset	01:00:00	01:05:00	
10	CHP	CC 106 isolator power	pending from B shift,,,FDR tripped in IEp picked up,Y phase I not coming from CT to siprotech	R and Y phase interchanged in siprotech relay,parameter changed for IEp(from 0.10 to .30)	22:00:00	23:15:00	to be normalized and ct to be checked
11	CHP	CC 131	OLR acted	reser	05:44:00	05:50:00	
12	CHP	CC 105 scr 10	LT not working,PCRD OT acted	reset	05:25:00	05:35:00	
13	CHP	CC 125	olr acted	reset	05:25:00	05:35:00	
14	CHP	CC 112 scr 8	no ligting,MCCB tripped	made it on	22:50:00	23:10:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/06/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	CHP	C 28	olr acted	reset	22:50:00	23:00:00	
16	CHP	CC 201	OLR acted	reset	00:40:00	00:50:00	