



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/07/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 28	BW 2 NOT RUNNING/OLR ACTED	RESET DONE	07:30:00	07:45:00	MATERIAL FALLING OUT SIDE
2	OHP	CO 26	TRIPPED ON OLR	RESET DONE	10:05:00	10:15:00	
3	CHP	CC 54	TRIPPED ON OLR	RESET DONE	10:00:00 10:30:00	10:10:00 10:40:00	
4	CHP	CC 131	TRIPPED ON OLR	RESET DONE	09:00:00	09:10:00	
5	CHP	SCR 9 ON CC 106	BC NOT RUNNING/ZSS ACTED/PROBE DAMAGED	PROBE REPLACED	10:20:00	10:35:00	
6	CHP	SCR 2 ON CC33	LT NOT TAKING PLACE/M1 TRIPPED	RESET DONE	12:50:00	13:00:00	
7	WT	CO 3	C/S ACTED.	C/S BYPASSED FOR OPERATION REQUIREMENT AT I/O RACK AND AGAIN KEPT IN CKT	10:30:00	10:45:00	