



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 26/05/2026

Incharge(s): Lal Singh

Shift: B

| Sl No | Area | Equipment    | Problem                                     | Action                                           | From     | To       | Remarks           |
|-------|------|--------------|---------------------------------------------|--------------------------------------------------|----------|----------|-------------------|
| 1     | OHP  | RSCO-10A CD  | TRIPPED ON OL                               | RESET DONE                                       | 14:40:00 | 14:50:00 |                   |
| 2     | OHP  | TT-3         | PCRD CABLE STUCK                            | UNWINDING AND WINDING DONE                       | 14:15:00 | 14:40:00 |                   |
| 3     | OHP  | CO-30 BRC    | ALL DRIVES NOT RUNNING ... R PHASE NO POWER | HT MADE OFF ... TRANSFORMER OPENING JOB GOING ON | 21:30:00 | 22:00:00 | CHECKING GOING ON |
| 4     | CHP  | CC-33 SCR-2  | SLEW DRIVE TRIP ON OL                       | RESET DONE                                       | 16:25:00 | 16:40:00 |                   |
| 5     | CHP  | CC-33 SCR-2  | BW DRIVE TRIPPED                            | RESET DONE                                       | 18:30:00 | 18:45:00 |                   |
| 6     | CHP  | CC-104 SCR-6 | TUL C/S ACTED ...MODULE PROBLEM BYPASSED    | MODULE CHANGED AND KEPT IN CKT                   | 18:50:00 | 19:05:00 |                   |
| 7     | CHP  | TT-3         | C/S MODULE PROBLEM                          | REPLACED AND TESTED                              | 16:35:00 | 17:35:00 |                   |
| 8     | CHP  | CC-54        | TRIPPED ON OLR                              | RESET DONE                                       | 17:05:00 | 17:10:00 |                   |