



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 12/07/2026

Incharge(s): P Venkat Kiran,P Venkat Kiran

Shift: B

| Sl No | Area | Equipment          | Problem                                                | Action                                                                                                                                | From                 | To                   | Remarks |
|-------|------|--------------------|--------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------|----------------------|----------------------|---------|
| 1     | OHP  | wobr-3 on co-25    | It not taking place                                    | pcrd overtension acted, released.                                                                                                     | 14:30:00             | 14:50:00             |         |
| 2     | OHP  | tbs-4 on co-5a     | no drives starting                                     | Control MCB was tripping as control bus termination screw was touching to back plate. proper tightening done and insulation provided. | 18:30:00             | 19:30:00             |         |
| 3     | OHP  | wobr-2 on co-29    | luff not taking place                                  | tripped on olr twice , reset done                                                                                                     | 18:00:00<br>19:30:00 | 18:15:00<br>19:45:00 |         |
| 4     | OHP  | co-111             | tripped on olr twice due to jamming at receiving chute | informed mechanical , operation and reset done.                                                                                       | 15:00:00<br>19:15:00 | 15:15:00<br>19:30:00 |         |
| 5     | OHP  | rsco-6a belt drive | tripped on olr                                         | reset done                                                                                                                            | 15:20:00             | 15:30:00             |         |
| 6     | CHP  | CC 125             | Olr acted                                              | Reset                                                                                                                                 | 16:30:00             | 16:40:00             |         |
| 7     | CHP  | Cc 103 T/T         | F/G trip                                               | Reset                                                                                                                                 | 14:30:00             | 14:40:00             |         |
| 8     | CHP  | SCR 9 on CC 213    | Communication Problem                                  | LT done                                                                                                                               | 15:30:00             | 15:45:00             |         |