



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 09/06/2026

Area: CHP

Equipment	Job
CC 7 side	Tunnel lighting improved
CM 24	PLC IO rack maintenance was done
CC 116,117	PPM was done
CM 28	Damaged lighting cable traced out and cut at cable tray
Elec scrap	Collected from yard area and placed at CM 17
CM 18	Rooms cleaning done