



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 09/06/2026

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 32	b/w 1 and 2 stopped in ZSS	ZSS bypassed	20:30:00	22:10:00	
2	OHP	co 26	olr acted	reset	20:30:00	20:40:00	
3	OHP	co 29	olr acted	reset	19:20:00	19:30:00	
4	CHP	CC 51	mpd tripped	reset	17:30:00	17:35:00	
5	CHP	CC 131	olr acted	reset	18:20:00	18:25:00	
6	CHP	CC 44	motor tripped	reset	19:50:00	20:00:00	
7	WT	OP 2	no movement,brake binding, pusher having heavy vibration,cascade contactor moving and fixed contact tip got welded	cascade contactor replaced,control checked found all ok,rack decoupled pusher moved smoothly decoupled	18:45:00 19:45:00	19:15:00 20:30:00	