



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 09/07/2026

Area: OHP

Equipment	Job
vs-1 motor	nde side sound observed, replaced motor.
vs-1 motor	nde side sound observed, replaced motor.
co-14a t/e gallery,	lighting is improved.
co-14a t/e gallery,	lighting is improved.
brc-2 on co-30	shifted from co-30 to repair bay, Transformer Replaced with spare one, charged and tested pcrd operation. provided additional lighting for mechanical jobs.
brc-2 on co-30	shifted from co-30 to repair bay, Transformer Replaced with spare one, charged and tested pcrd operation. provided additional lighting for mechanical jobs.