



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 11/07/2026

Area: OHP

Equipment	Job
co-34a to 36a	second chute vibrator fixing is under progress
co-34a to 36a	second chute vibrator fixing is under progress
co-33a,35a,37a	motor and panel side ppm is done
co-33a,35a,37a	motor and panel side ppm is done
co-9a,13a gallery, h/e area,stair case losp-2	lighting is improved
co-9a,13a gallery, h/e area,stair case losp-2	lighting is improved
vs-1 removed motor	sent to ers and spare motor shifted to vs level after coupling is fixed
vs-1 removed motor	sent to ers and spare motor shifted to vs level after coupling is fixed