



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/07/2026

Shift: B

Incharge(s): P Venkat Kiran,P Venkat Kiran

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC-5 on co-32	Hydraulic Pump-1 MCCB failed	replaced MCCB and trail run is taken.	14:00:00	15:45:00	