



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 22/09/2026

Area: OHP

Equipment	Job
co-16a,16b,17a,17b hoists	ppm is done
co-14b to co-20	chute vibrator is fixed and checked in auto mode.
co-36,37,47,48	motor and panel side ppm is done
RSCO-10A Belt drive panel outgoing	Running inspection defect observed and tightening was done.
co-11 panel outgoing	Running inspection defect observed and tightening was done.
brc-1 on co-30	BC direction changed, ZSS interlock cages and CJD swapped, to enable feeding towards co-31 ; on operational requirement.