



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 09/10/2026

Area: CHP

Equipment	Job
CC 28 TT	Cable jointed and spare cores traced
CC 222/223	Drive end one 200W fixture replaced
Tunnel air blower	Inspection done
SCR 8	Instrumentation sensors and belt scale maintenance was done
JHC 17,18,19,109,209,210,211,212	Hoists maintenance was done
JH C 209	Hoist brake adjusted
CC 35,S 2,CC 37,SCR 3	PPM was done
CC 130,131	PPM was done
CC 51	MCCB replaced and termination done