वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 16/10/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 44	Drive MCCB failed, Fuses Blown	Given in DOL	23:00:00	02:00:00	Drive to be checked
2	OHP	TBS on CO 24	Lt Drive trip	Reset	00:50:00	01:00:00	
3	OHP	BRC on CO 32	PCRD o/t acted	Released	04:05:00	04:20:00	
4	OHP	CO 29	OLR acted	Reset	23:30:00	06:00:00	2 times
5	OHP	VF 10 a	OLR acted	Reset	03:30:00	03:40:00	
6	CHP	CC 29 F/G	OLR acted	Reset	22:35:00	22:45:00	
7	CHP	CC 15	OLR acted	Reset	01:30:00	01:40:00	
8	WT	CO 4 CD	Not moving	Power Recycled then ok	22:40:00	22:45:00	