वी.एस.पी
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL SHIFT REPORT

Date: 13/11/2026

Shift: B

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|---|---|---|---|---|---|---|---|
| 1 | OHP | CO 25 | OLR acted | Reset | 15:30:00 | 19:00:00 | 2 times |
| 2 | OHP | BRC on CO 31 | Breaker tripped | Reset | 18:50:00 | 19:10:00 | |
| 3 | OHP | Co 26 | OLR acted | Reset | 20:40:00 | 21:40:00 | 2 times |
| 4 | OHP | WBR on co 29 | Main Breaker tripped | Made it on | 21:00:00 | 21:15:00 | |
| 5 | CHP | CC 51 | OLR acted | Reset | 18:30:00 | 20:00:00 | |
| 6 | CHP | CC 131 | OLR acted | Reset | 19:40:00 | 21:30:00 | |