वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 14/11/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VF 20	M2 Mpcb trip	Made it on	15:20:00	15:35:00	
2	OHP	WBr on CO 26	MPCB trip	Made it on	19:00:00	19:15:00	
3	OHP	BRC on CO 31 B/C	OLR acted	Reset	19:30:00	21:55:00	2 times
4	OHP	TIS 1	Power MPCB trip	Made it on	21:00:00	21:10:00	
5	CHP	SCR 5 on CC 32 B/c	Stopping in Rec mode	PLC power recycled	17:10:00	17:25:00	
6	CHP	SCR 9 on CC 104 Slew	MCCB trip	Made it on	20:20:00	20:35:00	