



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 12/05/2026

Area: CHP

Equipment	Job
Misc	COB-5 Stacking stream motors details noted
CC-54 H/E, CC-51 H/E HOISTS	PPM work done
CC-54	Panel and Motor PPM done
CC-130 MD, CC-52 MD	PPM work done
LC-17	Housekeeping done
STK-2	LT incoming isolator side, spark observed. Tightness done and tested OK
CC-49	From panel to PLC control cores continuity complaint rectified
CC-49	CJB TO T/E ZSS module new control cable laid and connections given. Kept in line
CC-31,SCR-1	PPM work done