



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/05/2026

Area: OHP

Equipment	Job
Yard LC and OM's	AC working status, dewatering pump status is checked.
wobr 25,26,6a	bucket wheel motors inspection is done wob-2 on co-25 bw motors belt canopy is provided on tb.. All space heaters inspection is done/
brc-4 on co-8a	repaired cabin fan is checked and installed at cabin.
co-34 brs	sensors canopy is provided.
wobr-3 on repair bay	limit switched ppm, It motors checking, are done.welding machine problem is rectified.
wobr-4 on co-6a	luff tb's were damaged, replaced them and solenoid terminations done and tested luff operations.
AF-8	checking is under progress.