



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/08/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	olr acted	reset	18:05:00	18:15:00	2 times
2	OHP	brc on co 34	CT not working,CT E pb acted	emrgency released	19:30:00	19:45:00	
3	OHP	BRC on CO 34	b/w 1 not running,jamming	informed operation and mechanical	20:00:00	20:15:00	
4	OHP	TBS on CO 21	all drive not working,control is off	control made on	20:40:00	21:00:00	
5	OHP	Co 111(b)	mpcb tripped	made it on	20:45:00	20:55:00	
6	CHP	CC 51	mpd acted	reset	19:45:00	19:50:00	2 times
7	CHP	cc 54	olr acted	reset	17:55:00	18:00:00	2 times
8	CHP	CC 40 scr 7	b/c not working,mpd acted	reset	17:00:00	17:10:00	