



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/07/2026

Incharge(s): G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	TRIPPED ON OLR	RESET DONE/2TIMES	01:05:00	01:15:00	
2	OHP	BRC ON CO 8A	BW 1 NOT RUNNING/GUIDE ROLLER FALLEN	INFORM TO OPE.	03:40:00	04:00:00	
3	OHP	CC 213	DRIVE TRIPPED ON TEMPERATURE FAULT	RESET DONE	02:50:00	03:05:00	
4	OHP	TT 1	FLAP GATE NOT WORKING/OLR ACTED	RESET DONE	05:30:00	05:40:00	
5	OHP	TT 3	LT NOT STOPPING/STOP PB STUCK UP	MADE FREE	00:56:00	02:10:00	STOP PB TO BE REPLACED
6	CHP	CC 125	TRIPPED ON OLR	RESET DONE	01:25:00	01:30:00	