RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 10/11/2026

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	Reported tripped	OLR acted.Reset done(2 times)	15:30:00	17:15:00	
2	OHP	TBS on CO-22	Left boom ZSS acting	Material jamming found in cage.Cleared and tested okay	14:20:00	14:45:00	
3	OHP	AF-1A	Reported tripped	Drive tripped on rotor stall.Reset done	16:40:00	16:44:00	
4	CHP	SCR-3 on CC-106	Right slewing not taking place	Jamming found	18:55:00	19:15:00	Informed to operation and after clearing tested okay
5	CHP	CC-14	Reported tripped	OLR acted.Reset done(2 times)	17:30:00	19:40:00	
6	CHP	CC-131	Reported tripped	OLR acted.Reset done	19:20:00	19:30:00	
7	WT	OP-4	Reported not moving	Breaker tripped in LC-2A.Made on and tested okay.Again tripped at 6.50pm.Made on	15:00:00	15:15:00	C clamp and jumper replaced after rake completion
8	IOSA	L and T WOBR	LT not taking place	PCRD tension acted.Released and tested okay	20:15:00	20:30:00	