RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 24/10/2026

Area: CHP

Equipment	Job
CC 55	PC kept in ckt
CC 107/215 /223 tunnels	Lighting inspection done and found ok
CC 105 BRS	Probes problem rectified and kept in ckt
SCR 8	Shifted from CC 106 to CC 213
All yards	HT couplers inspected
All JHs,LCs	Sump pump status inspected and noted
CC 15	PPM was done
HT I/C 2	Bus bar maintenance done
I/C 2,CC 213 I/C	Surrounding area cleaning done