



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/08/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	TRIPPED ON OLR	RESET DONE	06:55:00	07:05:00	
2	CHP	CC 131	TRIPPED ON OLR	RESET DONE	12:40:00	13:00:00	
3	CHP	SCR 8 ON CC 112	SLEW LEFT NOT WORKING 30 DEGREE LIMIT ACTED	LIMIT RESET DONE	07:20:00	07:30:00	
4	CHP	SCR 1 ON CC31	SLEW NOT WORKING/DRIVE TRIPPED ON OLR	RESET DONE	07:25:00	07:35:00	
5	CHP	SCR 5 ON CC 32	LT NOT TAKING PLACE/PCRD TENSION ACTED	TENSION RELEASED	11:20:00	11:30:00	