



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/08/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO 21	LT NOT TAKING PLACE/M1 OLR ACTED	RESET DONE/2TIMES	07:00:00 09:00:00	07:15:00 09:15:00	TRACK JAMMING
2	OHP	BRC ON CO 8A	NO DRIVES RUNNING/ACB TRIPPED	CAB MADE ON	11:30:00	11:45:00	
3	OHP	TBS ON CO 22	LT NOT TA KING PLACE/M2 OLR ACTED	RESET DONE	12:30:00	12:40:00	
4	CHP	CC 38	MPD TRIPPED ON OLR	RESET DONE	09:40:00	09:45:00	