



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/06/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO-7A	LT not stopping	Brakes to be adjusted	23:55:00	00:15:00	Informed to mechanical
2	OHP	CO-26	Reported tripped	OLR acted.Reset done	00:55:00	01:05:00	
3	CHP	CC-33 SCR-2	Reported LT not taking place	PCRD tension acted.Released	05:00:00	05:15:00	