वी.एस.पी
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL SHIFT REPORT

Date: 18/10/2026

Shift: C

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|---|---|---|---|---|---|---|---|
| 1 | OHP | WBR on CO 29 LT | No Electrical Problem | Informed to mech | 01:50:00 | 02:00:00 | |
| 2 | OHP | CO 25 | OLR acted | Reset | 02:10:00 | 02:55:00 | 2 times |
| 3 | OHP | VF 10a | OLR acted | Reset | 23:55:00 | 00:05:00 | |
| 4 | OHP | CO 34 | OLR acted | Reset | 02:00:00 | 02:40:00 | 2 Times |
| 5 | CHP | SCR 9 on CC 104 | Slew Control MCB trip | Made it on | 04:05:00 | 04:15:00 | |