



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 13/05/2026

Area: CHP

Equipment	Job
CC 109	BRS kept in ckt
CC 116 Gallary	3 nos 30W LED lamps replaced
CC 51,51A	PPM was done
CC 107/108 tunnel	11 nos 30W LED lamps replaced and improved lighting
110 KW	New motor 315SM received and placed at LBDS motor store
CC 33	Motor replaced ,alignment was done and trail run was taken.Burnt motor coupling removed and sent to ERS