



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 07/05/2026

Area: OHP

Equipment	Job
co-8,9,10	gallery cables inspection done, found ok.
co-6	motor side ppm is done.
cbms- on co-6a	motor side pinion removed for drawing development.
co-8a,30,31,32,65	chute vibrators ppm is done.
co-13a,14a,14b,rsc-6a ; co-38a,38b	motor and panel side ppm is done.
co-112 level, om-9, crusher-2 area, 47 gallery	lighting is improved.
tbs-4 on co-5a	pcrd guide problem , informed mechanical.
wobr-4	ppm is done
HT transformer	tank unloaded at HVMCC-1, leaks to be welded.
brc-5 on co-32	lighting circuit checked and rectified.
thruster brake for brc-4	preparation is done to be installed in brc-4 crmp side.
OHP yard HT cables	no. of joints and cables status checked.
brc-3 on co-34	shifted to co-33m, bw-2 start timer circuit rewired and trail run is taken. PCRD cable layering done properly.