



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 23/06/2026

Area: OHP

Equipment	Job
TBs-6 on co-7a	Spare Thruster brakes installed at M2 and M4
TBs-6 on co-7a	Spare Thruster brakes installed at M2 and M4
110 KW spare Hydraulic motor	Coupling is made ready and fixed.
110 KW spare Hydraulic motor	Coupling is made ready and fixed.
wobr-2 on co-29 ; co-29	motor and panel side ppm is done.
wobr-2 on co-29 ; co-29	motor and panel side ppm is done.
co-17,18 gallery ; JH O-4	lighting is improved. Circuit rectified, new lamps provided.
co-17,18 gallery ; JH O-4	lighting is improved. Circuit rectified, new lamps provided.
co-18; co-5 side sump pump	motor and panel side ppm is done. sump pump discharge pipe was damaged informed mechanical.
co-18; co-5 side sump pump	motor and panel side ppm is done. sump pump discharge pipe was damaged informed mechanical.