



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 26/09/2026

Area: CHP

Equipment	Job
CC 51 tunnel	De watering completed
JH C 5	2 nos 32A 4 pole MCBs replaced
S 3 on CC 34	HT cable jointed by DNW,termination done,3nos fuses replaced and charged power
All LCs,CMs	De watering inspected
Track Hopper	De watering under progress
CM 28	Outside belt scrap removed
RG 2,CC 130,CC 113	Chute vibrators ckt problems rectified and tested
CC 220	Lighting improved
SCR 8 on CC 112	Control cables inside cable chamber jointed