



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 10/09/2026

Area: CHP

Equipment	Job
CC112 to CC 38	HT couplers space heaters supply inspected ,rectified at two places
SCR 8	Instrumentation sensors maintenance was done
CC 220/221	Slope area 12 nos 30W LED lamps provided and 100mts cable laid
CC 111,SCR 4	PPM was done