



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 10/09/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav,M Kailash

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CR 1	mpr tripped due to ol	reset	02:10:00 23:25:00	02:25:00 23:40:00	
2	OHP	co 48	olr acted	reset	00:25:00	00:40:00	
3	CHP	cc 55 and 114	no power , I/C 2 tripped in LBDS 4,breaker spring is in discharged condition	in lbds 4 master relay is in tripped condition not getting set ,it reset after 10 minutes,spring charged,finally PNLno 36 made on in LBDS4	00:20:00	01:05:00	In LC19 I/C 2 made off and B/C made on***,to be normalized after stream stopped or in A shift***
4	CHP	CC 40 scr7	luff not working,pump is in off condition	pump made it on cmd	02:55:00	03:05:00	
5	CHP	CC 32	scr 5 B/c stoppped in ZSS,coal piece stucked in cage	cage cleaned	03:17:00	03:30:00	
6	CHP	CC 131	mpd acted	reset	05:25:00	05:30:00	
7	CHP	CC 28	flap gate motor mpcb tripped	amde it on	04:00:00	04:10:00	