



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 21/09/2026

Shift: A

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	tripped on olr	reset done	08:40:00 13:15:00	08:50:00 13:20:00	
2	OHP	WOBR ON CO 26	CABIN ADJUSTMENT NOT WORKING/MPCB TRIPPED	MPCB MADE ON	07:30:00	07:40:00	
3	OHP	VS 4A	TRIPPED ON OLR	RESET DONE	06:50:00	07:00:00	
4	OHP	VS 3A	TRIPPED ON OLR	RESET DONE	08:55:00	09:05:00	
5	OHP	CO 10A	TRIPPED ON OLR	RESET DONE	09:25:00 12:40:00	09:35:00 12:50:00	
6	OHP	CO 8	TRIPPED ON OVER CURRENT (IMB FAULT)/CHECKED AND FOUND RESISTANCE and INDUCTANCE LOW VALUES SMOKE OBSERVED	MOTOR TO BE CHANGED	11:25:00	13:30:00	3TIMES
7	OHP	TBS ON CO 5A	NO DRIVES RUNNING/CONTROL TRIPPED	CONTROL MADE ON	12:00:00	12:15:00	
8	CHP	SCR 4 ON CC111	LT NOT TAKING PLACE/PCRD TENSION ACTED	TENSION RELEASED	07:45:00	08:00:00	
9	CHP	SCR 2 ON CC33	BW NOT WORKING/OLR ACTED	RESET DONE	09:35:00	09:50:00	
10	CHP	SCR 3ON CC37	LT NOT TAKING PLACE/DRIVE TRIPPED	RESET DONE	10:10:00	10:25:00	
11	CHP	CC 48	C/S ACTED DUE TO CHUTE JAMMING	INFORM TO OPERATION	10:35:00	10:55:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/09/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC 52	TRIPPED ON OLR	RESET DONE	09:00:00	09:10:00	FEEDING CONV. STOPPED