



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 08/08/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

| Sl No | Area | Equipment    | Problem                              | Action                            | From     | To       | Remarks |
|-------|------|--------------|--------------------------------------|-----------------------------------|----------|----------|---------|
| 1     | OHP  | co 26        | olr acted                            | reset                             | 18:05:00 | 18:15:00 | 2 times |
| 2     | OHP  | brc on co 34 | CT not working,CT E pb acted         | emrgency released                 | 19:30:00 | 19:45:00 |         |
| 3     | OHP  | BRC on CO 34 | b/w 1 not running,jamming            | informed operation and mechanical | 20:00:00 | 20:15:00 |         |
| 4     | OHP  | TBS on CO 21 | all drive not working,control is off | control made on                   | 20:40:00 | 21:00:00 |         |
| 5     | OHP  | Co 111(b)    | mpcb tripped                         | made it on                        | 20:45:00 | 20:55:00 |         |
| 6     | CHP  | CC 51        | mpd acted                            | reset                             | 19:45:00 | 19:50:00 | 2 times |
| 7     | CHP  | cc 54        | olr acted                            | reset                             | 17:55:00 | 18:00:00 | 2 times |
| 8     | CHP  | CC 40 scr 7  | b/c not working,mpd acted            | reset                             | 17:00:00 | 17:10:00 |         |