



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 28/08/2026

Area: CHP

Equipment	Job
CC 212	BRS WIRING COMPLETED UPTO VFD PANEL
JH C 9	Hoist brake shoe replaced and tested the brake
LC 18,13,CM 28	Rooms cleaning was done
CC 105,106	Running inspection was done
Rock Well	PLC maintenance was done
COB 5	Reclaiming stream trail run was taken
JH C 17	Sump pump motor replaced and trail run was taken
CCR Road	New lighting poles lamp fixtures fixed and power charged