



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/05/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	SCR 7 O CC 39 NO DRIVE WORKING	BREAKER TRIPPED	MADE IT ON	00:20:00	00:30:00	
2	CHP	SCR 1 ON CC 31	SLEW DRIVE TRIPPED	RESET	02:50:00	03:00:00	
3	CHP	SCR 6 ON CC 104 LT	M2 TRIP	MADE IT ON	03:00:00	03:10:00	