



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/07/2026

Incharge(s): P Venkat Kiran,P Venkat Kiran

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC-5 on co-32	Hydraulic Pump-1 MCCB failed	replaced MCCB and trail run is taken.	14:00:00	15:45:00	
2	OHP	co-7a zss	cage got stuck	cage replaced and tested	15:30:00	16:10:00	
3	OHP	wbr-3 on co-25 bw	not starting	found mpcb in off condition, made on	18:50:00	19:00:00	
4	OHP	vs-2a	estop not released properly	made free and released	19:55:00	20:10:00	
5	CHP	CC 125	OLR acted	Reset	20:55:00	21:00:00	
6	CHP	CC 131	OLR acted	Reset	17:30:00	17:35:00	
7	WT	OT 3	Drive1 tripped	Reset	18:40:00	18:45:00	