



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 08/10/2026

Incharge(s): Amit Roy

Shift: C

| Sl No | Area | Equipment      | Problem             | Action                      | From     | To       | Remarks                          |
|-------|------|----------------|---------------------|-----------------------------|----------|----------|----------------------------------|
| 1     | OHP  | BRC on CO-30   | CT not taking place | Drive tripped.Reset done    | 02:50:00 | 03:05:00 |                                  |
| 2     | OHP  | CO-26          | Reported tripped    | OLR acted.Reset done        | 03:55:00 | 03:45:00 |                                  |
| 3     | OHP  | CO-10A         | Reported tripped    | OLR acted.Reset done        | 05:05:00 | 05:15:00 |                                  |
| 4     | OHP  | BRC on CO-32   | PCRD tension acted  | Manually made down          | 04:35:00 | 04:50:00 | To be checked and to be rectfied |
| 5     | CHP  | S-3 on CC-112  | B/C not running     | OLR acted.Reset done        | 22:50:00 | 23:05:00 |                                  |
| 6     | CHP  | SCR-5 on CC-32 | LT not taking place | PCRD tension acted.Released | 00:45:00 | 01:00:00 |                                  |