



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/09/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR acted	Reset	20:50:00	21:00:00	
2	CHP	CC 131	OLR acted	Reset	15:30:00	21:00:00	5 Times
3	CHP	SCR 7 on CC 40	Luff MPD trip	Reset	20:10:00	20:25:00	
4	CHP	CC 22	ZSS Module to Probe cable Problem	Bypassed	20:20:00	20:40:00	Cable Changing under progress
5	CHP	CC 28 to CC 33	Glass fuse blown	Replaced	21:15:00	21:30:00	