



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 09/07/2026

Area: OHP

Equipment	Job
brc-2 on co-30	shifted from co-30 to repair bay, Transformer Replaced with spare one, charged and tested pcrd operation. provided additional lighting for mechanical jobs.
brc-2 on co-30	shifted from co-30 to repair bay, Transformer Replaced with spare one, charged and tested pcrd operation. provided additional lighting for mechanical jobs.