



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/07/2026

Shift: B

Incharge(s): P Venkat Kiran,P Venkat Kiran

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	vs-1 motor	NDE side bearing sound observed,	motor changed with spare one and trail run is rakrn.	14:45:00	16:45:00	