RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 30/10/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO 6A(c)	olr acted	reset	15:45:00	16:00:00	
2	OHP	RSCo9A(c)	mpcb tripped	reset	17:00:00	17:10:00	
3	OHP	CC 105 scr 10	LT not working,OT acted	released	14:50:00	15:00:00	
4	OHP	co 26	olr acted	reset	18:00:00	18:10:00	3 times
5	OHP	wobr on co 29	LT not working,drive tripped in OL	reset,checked and found D1 gear box oil leakage	18:00:00	18:15:00	3 times tripped in ol,kept in DOL mode
6	OHP	TBSc on Co20	R BC luffing not working,olr acted	reset	17:25:00	17:35:00	
7	OHP	CO 25	olr acted	reset	18:25:00	18:35:00	2 times
8	CHP	CC 14	zss acted,coal stucked in cage	cage cleaned	18:00:00	18:10:00	
9	CHP	CC 51A	zss acted 2 times,stone stucked	removed	19:40:00	19:50:00	
10	CHP	CC 37 SCR3	LUFF not working,oil level low	informed mechanical	15:30:00	15:40:00	
11	CHP	CC 105 scr10	slew not working,coal jamming in slew area	informed operation	18:05:00	18:15:00	