



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/07/2026

Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	OLR ACTED (2TIMES)	RESET DONE	18:20:00 20:10:00	18:30:00 20:20:00	
2	OHP	WOBR ON CO-29	REPORTED SLEW NOT TAKING PLACE DRIVE TRIP CHECKED AND FOUND BRAKE NOT RELEASED	DRIVE RESET AND SLEW BRAKE LOOSEMED BY MECHANICAL THAN OK	19:00:00	19:30:00	
3	OHP	TT-2	LT MPCB TRIP	MADE ON THAN OK	15:00:00	15:10:00	
4	OHP	TIS-2	MPCB TRIP	MADE ON THAN PK	16:40:00	17:00:00	
5	CHP	CC-52	CONTROL MCB TRIP	MADE ON THAN OK	19:15:00	19:20:00	
6	CHP	CC-114	REPORTED NOT HEALTHY CHECKED AND FOUND PC ACTED	PULL CHORD RESET DONE THAN OK	16:35:00	16:45:00	
7	CHP	CC-36 S-1	SLEW NOT WORKING DRIVE TRIP SLEW RIGHT MOTOR PINION NOT ROTATING	RESET DONE AND INFORMED TO MECHANICAL	17:05:00	17:20:00	